



INFORMATION SHEET FOR AIR CONDITIONERS, EXCEPT DOUBLE DUCTS AND SINGLE DUCTS⁽⁵⁾

As by Commission Communication in the framework of ecodesign requirements for air conditioners and comfort fans (EU Regulation no. 206/2012) and of energy labelling of air conditioners - (EU Regulation no. 626/2011)

Appendix I: information according to clause 3 of NO 206/2012 ANNEX I , for air conditioners, except single duct and double duct air conditioners

MODEL : ASG ECO 50PH / AEG ECO50PIH

| Function (indicate if present) | | | | Only for heating mode, if applicable | | | |
|--|----------|-------|------|---|--------|-------|------|
| Cooling | Y | | | Average(mandatory) | Y | | |
| Heating | Y | | | Warmer(if designed) | N | | |
| | | | | Colder(if designed) | N | | |
| Item | Symbol | Value | Unit | Item | Symbol | Value | Unit |
| Design load | | | | Seasonal efficiency | | | |
| Cooling | Pdesignc | 5.0 | kW | Cooling | SEER | 5.9 | — |
| Heating/average | Pdesignh | 4.0 | kW | Heating/average | SCOP/A | 4.0 | — |
| Heating/warmer | Pdesignh | x,x | kW | Heating/warmer | SCOP/W | x,x | — |
| Heating/colder | Pdesignh | x,x | kW | Heating/colder | SCOP/C | x,x | — |
| Declared capacity (*) for cooling, at indoor temperature 27(19) °C and outdoor temperature Tj | | | | Declared energy efficiency ratio (*), at indoor temperature 27(19) °C and outdoor temperature Tj | | | |
| Item | Symbol | Value | Unit | Item | Symbol | Value | Unit |
| Tj=35°C | Pdc | 5.00 | kW | Tj=35°C | EERd | 3.20 | — |
| Tj=30°C | Pdc | 3.59 | kW | Tj=30°C | EERd | 4.66 | — |
| Tj=25°C | Pdc | 2.27 | kW | Tj=25°C | EERd | 6.50 | — |
| Tj=20°C | Pdc | 1.26 | kW | Tj=20°C | EERd | 10.20 | — |
| Declared capacity (*) for heating/Average season, at indoor temperature 20 °C and outdoor temperature Tj | | | | Declared coefficient of performance(*)/Average season, at indoor temperature 20 °C and outdoor temperature Tj | | | |
| Tj=-7°C | Pdh | 3.63 | kW | Tj=-7°C | COPd | 2.71 | — |
| Tj=2°C | Pdh | 2.11 | kW | Tj=2°C | COPd | 3.96 | — |
| Tj=7°C | Pdh | 1.42 | kW | Tj=7°C | COPd | 5.00 | — |
| Tj=12°C | Pdh | 1.50 | kW | Tj=12°C | COPd | 6.10 | — |
| Tj=operating limit | Pdh | 3.68 | kW | Tj=operating limit | COPd | 2.68 | — |
| Tj=bivalent temperature | Pdh | 3.63 | kW | Tj=bivalent temperature | COPd | 2.71 | — |

| | | | | | | | |
|---|------------------|-------------------|----|--|-----------------|------|-------|
| Declared capacity (*) for heating/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj | | | | Declared coefficient of performance(*)/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj | | | |
| Tj=2°C | Pdh | x,x | kW | Tj=2°C | COPd | x,x | — |
| Tj=7°C | Pdh | x,x | kW | Tj=7°C | COPd | x,x | — |
| Tj=12°C | Pdh | x,x | kW | Tj=12°C | COPd | x,x | — |
| Tj=operating limit | Pdh | x,x | kW | Tj=operating limit | COPd | x,x | — |
| Tj=bivalent temperature | Pdh | x,x | kW | Tj=bivalent temperature | COPd | x,x | — |
| Declared capacity (*) for heating/Colder season, at indoor temperature 20 °C and outdoor temperature Tj | | | | Declared coefficient of performance(*)/Colder season, at indoor temperature 20 °C and outdoor temperature Tj | | | |
| Tj=-7°C | Pdh | x,x | kW | Tj=-7°C | COPd | x,x | — |
| Tj=2°C | Pdh | x,x | kW | Tj=2°C | COPd | x,x | — |
| Tj=7°C | Pdh | x,x | kW | Tj=7°C | COPd | x,x | — |
| Tj=12°C | Pdh | x,x | kW | Tj=12°C | COPd | x,x | — |
| Tj=operating limit | Pdh | x,x | kW | Tj=operating limit | COPd | x,x | — |
| Tj=bivalent temperature | Pdh | x,x | kW | Tj=bivalent temperature | COPd | x,x | — |
| Tj=-15°C | Pdh | x,x | kW | Tj=-15°C | COPd | x,x | — |
| Bivalent temperature | | | | Operating limit temperature | | | |
| Heating/Average | Tbiv | -7 | °C | Heating/Average | Tol | -10 | °C |
| Heating/Warmer | Tbiv | x | °C | Heating/Warmer | Tol | x | °C |
| Heating/Colder | Tbiv | x | °C | Heating/Colder | Tol | x | °C |
| Cycling interval capacity | | | | Cycling interval efficiency | | | |
| for cooling | Pcycc | x,x | kW | for cooling | EERcyc | x,x | — |
| for heating | Pcyh | x,x | kW | for heating | COPcyc | x,x | — |
| Degradation coefficient cooling (**) | Cdc | 0.25 | — | Degradation coefficient heating (**) | Cdh | 0.25 | — |
| Electric power input in power modes other than 'active mode' | | | | Annual electricity consumption | | | |
| Off mode | P _{OFF} | 0.002792 | kW | Cooling | Q _{CE} | 297 | kWh/a |
| Standby mode | P _{SB} | 0.002792 | kW | Heating/Average | Q _{HE} | 1400 | kWh/a |
| Thermostat-off mode | P _{TO} | 0.010979/0.020994 | kW | Heating/Warmer | Q _{HE} | -- | kWh/a |
| Crankcase heater mode | P _{CK} | 0 | kW | Heating/Colder | Q _{HE} | -- | kWh/a |
| | | | | | | | |

| Capacity control (indicate one of three options) | | Other items | | | |
|--|---|--|-----------------|----------------|-----------------------|
| fixed | N | Sound power level (indoor/outdoor) | L _{WA} | (60/65) | dB(A) |
| staged | N | Global warming potential | GWP | 675 | kgCO ₂ eq. |
| variable | Y | Rated air flow (indoor/outdoor) | — | (700/3000) | m ³ /h |
| Contact details for obtaining more information | | Argoclima spa – Via Alfeno varo, 35 – 25020 Alfianello (BS) – Italy www.argoclima.com | | | |
| <p>(*) For staged capacity units, two values divided by a slash (/) will be declared in each box in the section 'Declared capacity of the unit' and 'declared EER/COP' of the unit.</p> <p>(**) If default Cd = 0,25 is chosen then (results from) cycling tests are not required. Otherwise either the heating or cooling cycling test value is required.</p> <p>For units with capacity control marked 'staged', two values for the highest and lowest, noted 'hi/lo' divided by a slash (/) will be declared in each box under 'Declared capacity'.</p> | | | | | |



Product Fiche

The basic information

Model: ASG ECO 50PH + AEG ECO 50PIH

Manufacturer : ARGOCLIMA SPA - via Alfeno Varo, 35 - Alfianello (BS) - Italy;

Sound power level (indoor unit / outdoor unit): 60/65 dB(A);

Refrigerant: R32 ;

Refrigerant leakage contributes to climate change. Refrigerant with lower global warming potential (GWP) would contribute less to global warming than a refrigerant with higher GWP, if leaked to the atmosphere. This appliance contains a refrigerant fluid with a GWP equal to 675 .This means that if 1 kg of this refrigerant fluid would be leaked to the atmosphere, the impact on global warming would be 675 times higher than 1 kg of CO₂, over a period of 100 years. Never try to interfere with the refrigerant circuit yourself or disassemble the product yourself and always ask a professional.

Cooling mode

SEER: 5.9 ;

Energy efficiency class: A+ ;

Pdesignc: 5.0 kW;

Energy consumption 297 kWh per year, based on standard test results.

Actual energy consumption will depend on how the appliance is used and where it is located.

Heating mode

Type: Average ;

SCOP: 4.0 ;

Energy efficiency class: A+ ;

Pdesignh: 4.0 kW;

Energy consumption 1400 kWh per year, based on standard test results.

Actual energy consumption will depend on how the appliance is used and where it is located.

The back up heating capacity for calculation of SCOP at reference design condition: 0.3kw